

Emission Test Certificate

Wednesday, 3rd April 2013

Supplier: Armstrong World Industries (99 Derby St, Silverwater, NSW, 2128)

Sample Description: Dune Ceiling Tile

Date Tested: February 2013 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Green Building Council of Australia Green Star Office Design IEQ-13	Dune Ceiling Tile
Total Volatile Organic Compound Emission Rate Limit <math><0.5\text{mg}/\text{m}^2/\text{hr}</math>	<math><0.005\text{ mg}/\text{m}^2/\text{hr}</math> (24 hours)
Formaldehyde Emission Rate Limit: <math><0.1\text{mg}/\text{m}^2/\text{hr}</math>	0.016 $\text{mg}/\text{m}^2/\text{hr}$ (24 hours) 0.009 mg/m^3 (24 hours)*

**Based on the Standard Room Calculation*



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc(Biotechnology)
Consultant

CV130222