

Emission Test Certificate

Wednesday, 3rd April 2013

Supplier: Armstrong World Industries (99 Derby St, Silverwater, NSW, 2128)

Sample Description: Fine Fissured Ceiling Tile

Date Tested: February 2013 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p align="center">Green Building Council of Australia Green Star Office Design IEQ-13</p>	<p align="center">Fine Fissured Ceiling Tile</p>
<p>Total Volatile Organic Compound Emission Rate Limit <0.5mg/m²/hr</p>	<p align="center"><0.008 mg/m²/hr (24 hours)</p>
<p>Formaldehyde Emission Rate Limit: <0.1mg/m²/hr</p>	<p align="center"><0.009 mg/m²/hr (24 hours) <0.005 mg/m³ (24 hours)*</p>

**Based on the Standard Room Calculation*



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc(Biotechnology)
Consultant

CV130222