

VOC Content Test Certificate

Friday 8th October 2021

Supplier: DEGAFLOOR NZ (6 Sheffield Street, Levin, 5510, New Zealand).

Sample Description: DEGADUR® 112

Date Tested: September 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

Specification New Zealand Green Building Council Green Star – Design & As Built NZ V1.0-13.1.1B Green Star Interiors V1.0-12.1.1B	DEGADUR® 112
One and two pack performance coatings for floors: 140 grams per liter	15 grams per Litre as VOC content per material
<i>We hereby certify that Degadur® 112 product is below the VOC Content limits of chosen categories specified by New Zealand Green Building Council, Green Star Design & As Built, and Green Star Interiors</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant

V2109049

VOC Content Test Certificate

Friday 8th October 2021

Supplier: DEGAFLOOR NZ (6 Sheffield Street, Levin, 5510, New Zealand).

Sample Description: DEGADUR® 420

Date Tested: September 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

Specification New Zealand Green Building Council Green Star – Design & As Built NZ V1.0-13.1.1B Green Star Interiors V1.0-12.1.1B	DEGADUR® 420
One and two pack performance coatings for floors: 140 grams per liter	61 grams per Litre as VOC content per material
<i>We hereby certify that Degadur® 420 product is below the VOC Content limits of chosen categories specified by New Zealand Green Building Council, Green Star Design & As Built, and Green Star Interiors</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant

V2109049

VOC Content Test Certificate

Friday 8th October 2021

Supplier: DEGAFLOOR NZ (6 Sheffield Street, Levin, 5510, New Zealand).

Sample Description: DEGADUR® 526

Date Tested: September 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:


Specification New Zealand Green Building Council Green Star – Design & As Built NZ V1.0-13.1.1B Green Star Interiors V1.0-12.1.1B	DEGADUR® 526
One and two pack performance coatings for floors: 140 grams per liter	18 grams per Litre as VOC content per material
<i>We hereby certify that Degadur® 526 product is below the VOC Content limits of chosen categories specified by New Zealand Green Building Council, Green Star Design & As Built, and Green Star Interiors</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant

V2109049

VOC Content Test Certificate

Friday 8th October 2021

Supplier: DEGAFLOOR NZ (6 Sheffield Street, Levin, 5510, New Zealand).

Sample Description: DEGADUR® 527

Date Tested: September 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

Specification New Zealand Green Building Council Green Star – Design & As Built NZ V1.0-13.1.1B Green Star Interiors V1.0-12.1.1B	DEGADUR® 527
One and two pack performance coatings for floors: 140 grams per liter	12 grams per Litre as VOC content per material
<i>We hereby certify that Degadur® 527 product is below the VOC Content limits of chosen categories specified by New Zealand Green Building Council, Green Star Design & As Built, and Green Star Interiors</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant

V2109049