



- Green Building Summary Sheet -

Author

EnviroSpec Verification Services

Document Type

Green Building Rating Compatibility Analysis

Document Code

ES-GSNZ-10-15c

Validity

Office 2009 + V3 ✓ Interiors 2009 + V3 ✓ Education 2009 + V3 + V3.1 ✓ Industrial 2009 + V3 ✓	Homestar V2 + V3 ✓	V 1.1 -	(not assessed) -

Client

Sika NZ Ltd.

Product Name

Sikaflex® 11 FC

Product Description

Sikaflex 11FC is a one component polyurethane joint sealant and adhesive. Sikaflex 11FC is a non-slumping material that cures by reaction with atmospheric moisture to form a tough and resilient elastomer. This product has a movement capacity of +/-10% and the shore hardness value of 40. This product has been independently certified as low VOC in accordance with the calculation methodology nominated in the Green Star NZ Technical manuals

**Manner in which the product may contribute towards points****Legend of Symbols in EnviroSpec**

Products must meet specific criteria (e.g. Paint VOC emissions, carpets, etc)



Products may help achieve points by their very nature, if they are specified and installed (e.g. bicycle racks)



Products may help achieve an outcome but they must be used in a specific manner (e.g. lighting control and zoning systems) OR The nominated product can contribute towards the outcome but many other products or factor influence that same outcome (E.g. Potable Water Calculator)

**Disclaimer - Please read this carefully**

Each Building Environmental Rating Tool and Scheme nominated herein is owned and operated by its respective operative organisation, independently of EnviroSpec Ltd., and EnviroSpec Ltd. equally operates independently of any nominated rating scheme. The information represented on EnviroSpec is not endorsed by any of these organisations in a direct manner and any decision regarding final approval or refusal of points and certifications where the nominated product is used is at the final discretion of the respective owners and operators of the nominated Building Environmental Rating Schemes, and any network of assessors or auditors that are accredited to operate under their assessment structure, in accordance with all associated technical manuals, rules and guidelines. For detailed technical information about each Building Environmental Rating Schemes and product related criteria please refer to the appropriate technical manuals. EnviroSpec does not accept liability for any loss or damages resulting from the use of this document and emphasizes that this document is provided as guidance only. Use of, or reliance upon, any information contained in this report is at the user's own risk. The information presented in this report is valid for the Building Environmental Rating Schemes and Tools nominated herein only. As and when the respective owners and operators publish updates or new tools, the information may require updating. EnviroSpec Ltd. will only update information in this report upon receiving written consent from the Manufacturer, Supplier or upon request from an operative organisation of one of the Building Environmental Rating Tools nominated herein. **It is the responsibility of the reader to check for regular updates.**



- Green Building Summary Sheet -

Tool	Credit category	Points available	Requirements	Contribution symbol	Contribution Potential	Details of compliance
Green Star NZ Office 2009 + Education (2009 and V3) + Industrial 2009 + Interiors 2009	IEQ-3	5	This credit rewards the use of low formaldehyde composite timber products, as well as low VOC applied coatings, floor coverings, interior fitout items, sealants and adhesives, or the avoidance of these products in the first place.		1 point (out of 1 point available for sealants and adhesives)	This product is low VOC in accordance with the correct calculation methodology and satisfies this requirement.
Green Star NZ Office V3.0 + Education V3.1 + Industrial V3	MAT-4	5	This credit rewards up to 5 points in total. • 4 points are allocated for the use of low VOC and low formaldehyde emitting products (including Applied coatings, Adhesives & Sealants, Flooring, Ceilings, Internal walls & partitions) – Each product type is worth up to 1 point. <u>Benchmarks are:</u> - 0.5 points are awarded if > 50% of a selected product type complies - 1 point is awarded if > 90% of a selected product type complies. • 1 point is allocated for the use of low formaldehyde emitting engineered wood products (exposed or concealed applications) 90% complies.		1 point	The nominated product satisfies the credit criteria for low VOC emissions.
Green Star NZ Interiors V3	MAT-4	6	This credit rewards up to 6 points in total. • 5 points are allocated for the use of low VOC and low formaldehyde emitting products (including Applied coatings, Adhesives & Sealants, Flooring, Ceilings, Internal walls & partitions + Fitout items) – Each product type is worth up to 1 point. <u>Benchmarks are:</u> - 0.5 points are awarded if > 50% of a selected product type complies - 1 point is awarded if > 90% of a selected product type complies. • 1 point is allocated for the use of low formaldehyde emitting engineered wood products (exposed or concealed applications) 90% complies.		1 point	The nominated product satisfies the credit criteria for low VOC emissions.
Homestar (V2 and V3)	MAT - 2	3	This credit rewards the use of low formaldehyde composite timber products, as well as low VOC paints, carpets and adhesives or the avoidance of these products in the first place. The Homestar Technical manual currently states specific VOC limits for sealants and adhesives.		0.75 points (out of 0.75 points available for sealants and adhesives)	This product is low VOC in accordance with the correct calculation methodology and satisfies this requirement.
Living Building Challenge		Pass/Fail	The nominated product has not been assessed against this criteria.	-	-	The nominated product has not been assessed against this standard.
SBN Circular Economy Office Model V1.1		Pass/Fail	The nominated product has not been assessed against this criteria.	-	-	The nominated product has not been assessed against this standard.