

Emission Test Certificate

Wednesday November 16th, 2005

Supplier: Interface Australia Pty Ltd (4 Henry Street, Picton NSW 2511)

Sample Description: GlasBacRE

Date Tested: November 2005

Test Method: Carpet & Rug Institute Green Label Plus test program incorporating
ASTM D5116-97 "Standard Guide for Small-Scale Environmental Chamber
Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

Carpet & Rug Institute Green Label Plus Specification	GlasBacRE
Total Volatile Organic Compound emission rate < 0.5 mg/m ² /hr (14 days)	The results for "GlassBacRE" can be considered representative of the whole range of solution dyed nylon modular carpet with GlasBac, GlasBacRE and System Six backing
<p>"Chemicals of Concern":</p> <ul style="list-style-type: none"> Formaldehyde Acetaldehyde Benzene Caprolactam 2-Ethylhexanoic Acid 1-Methyl-2-Pyrrolidinone Naphthalene Nonanal Octanal 4-Phenylcyclohexene Styrene Toluene Vinyl Acetate 	<p>Emission Rate:</p> <ul style="list-style-type: none"> 0.001 mg/m²/hr 0.006 mg/m²/hr <0.002 mg/m²/hr <0.002 mg/m²/hr <0.007 mg/m²/hr <0.003 mg/m²/hr <0.002 mg/m²/hr <0.002 mg/m²/hr <0.002 mg/m²/hr <0.002 mg/m²/hr <0.002 mg/m²/hr 0.002 mg/m²/hr <0.002 mg/m²/hr <p>The "chemicals of concern" were present in the product to a very low extent and would pose insignificant health effect to building occupants when used in the typical manner.</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ, ACA, AIRAH, FMA
Managing Director and Principal Consultant