

VOC Content Test Certificate

Friday August 14th, 2009

Manufacturer: Sika New Zealand (85 – 91 Patiki Road, Avondale Auckland New Zealand 1746)

Sample Description: Sikaflex AT Façade high performance movement joint sealant

Date Tested: August 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in

Various Materials as referenced by South Coast Air Quality Management Division

(SCAQMD) Rule 1168.

Test Data:

Specification	
Green Building Council of Australia	Sikaflex AT Facade
Green Star Office Design V2 IEQ-13	
Green Star Office Interiors V1.1 IEQ-11	
New Zealand Green Building Council	
Green Star NZ Office 2009 IEQ-3	
Green Star NZ Office Interiors IEQ-3	
Architectural sealant 250 grams per Litre as	18 grams per Litre as VOC content
VOC content material	material
Specification	
Green Building Council of Australia	Sikaflex AT Facade
Green Star Office Design V3 IEQ-13	
Architectural sealant 250 grams per Litre as	18 grams per Litre as VOC content
VOC content material	material

Dr. Vyt Garnys

PhD, BSc(Hons) AIMM, ARACI, ISIAQ

ACA, AIRAH, FMA

Managing Director and Principal Consultant

F0908-08