

# Emission Test Certificate

Wednesday, 27<sup>th</sup> October, 2010

Supplier: Polyflor Australia Pty Ltd (59-65 Wedgewood Road, Hallam, VIC, 3803)

Sample Description: Polyflor Classic Mystique PUR homogeneous Vinyl Flooring 2mm, Shade 1410 Ladoga, 3.25kg/m<sup>2</sup>, Batch: 7z154

Date Tested: September 2010 (Tested by FORAY Laboratories – ISO 17025 Accredited)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<b>Specification</b> <b>Green Building Council of Australia</b> <b>Green Star Office Design IEQ-13</b> <b>Green Star Office Interiors IEQ-11</b>	<b>Polyflor Classic Mystique PUR</b>
Total Volatile Organic Compound emission rate <0.5 mg/m <sup>2</sup> /hr	Total Volatile Organic Compound emission rate 0.04 mg/m <sup>2</sup> /hr
<i>The Green Building Council of Australia recommends a threshold limit of 0.5 milligrams per square meter per hour; in accordance with this threshold this product would meet the recommended requirements.</i>	

*The above results can be considered as representative of the homogeneous Vinyl Flooring group of products including Polyflor Pearlazzo PUR, Polyflor Prestige PUR, Polyflor 2000 PUR, Polyflor XL PUR, Polyflor Mystique PUR and Polyflor Standard XL as advised by Polyflor Australia Pty Ltd.*



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

CV100838