



Professional Scientific Solutions

VOC Content Test Certificate

Tuesday July 1st, 2008

Manufacturer: Sika New Zealand (85 – 91 Patiki Road, Avondale Auckland New Zealand 1746)

Sample Description: Sikadur 51 two component joint sealant

Date Tested: June 2008 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification	
Green Building Council of Australia	Sikadur 51
Green Star Office Design V2 IEQ-13	
Green Star Office Interiors V1.1 IEQ-11	
New Zealand Green Building Council	
Green Star NZ Office 2009 IEQ-3	
Green Star NZ Office Interiors IEQ-3	
Architectural sealant 250 grams per Litre as VOC content material	29 grams per Litre as VOC content material
Specification	
Green Building Council of Australia	Sikadur 51
Green Star Office Design V3 IEQ-13	
Architectural sealant 250 grams per Litre as VOC content material	29 grams per Litre as VOC content material

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0806-27