

# VOC Content Test Certificate

Tuesday May 4<sup>th</sup>, 2010

Manufacturer: Peter Fell Ltd (81 Patiki Road, Rosebank, Auckland, New Zealand 1142)

Sample Description: PFL Acrylic Sealer

Date Tested: April 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings.

Test Data:

<b>Specification</b>	
<p><b>New Zealand Green Building Council</b>  <b>Green Star NZ Office 2009 IEQ-3</b>  <b>Green Star NZ Office Interiors IEQ-3</b>  <b>Green Building Council of Australia</b>  <b>Green Star Office Design V2 IEQ-13</b>  <b>Green Star Office Interiors V1.1 IEQ-11</b></p>	<b>PFL Acrylic Sealer</b>
Interior Sealer 65 grams per Litre as VOC content material	35 grams per Litre as VOC content per material
<b>Specification</b>	
<p><b>Green Building Council of Australia</b>  <b>Green Star Office Design V3 IEQ-13</b></p>	<b>PFL Acrylic Sealer</b>
Interior Sealer 65 grams per Litre as VOC content material	35 grams per Litre as VOC content per material



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant

**F1004-21**