

VOC Content Test Certificate

Monday May 17th, 2010

Manufacturer: Peter Fell Ltd (81 Patiki Road, Rosebank, Auckland, New Zealand 1142)

Sample Description: PFL Epoxy Sealer

Date Tested: May 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings.

Test Data:

Specification	
<p>New Zealand Green Building Council</p> <p>Green Star NZ Office 2009 IEQ-3</p> <p>Green Star NZ Office Interiors IEQ-3</p> <p>Green Building Council of Australia</p> <p>Green Star Office Design V2 IEQ-13</p> <p>Green Star Office Interiors V1.1 IEQ-11</p>	PFL Epoxy Sealer
Interior Sealer 65 grams per Litre as VOC content material	<30 grams per Litre as VOC content per material
Specification	
<p>Green Building Council of Australia</p> <p>Green Star Office Design V3 IEQ-13</p>	PFL Epoxy Sealer
Interior Sealer 65 grams per Litre as VOC content material	<30 grams per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1004-21