

Emission Test Certificate

Wednesday, 27th October, 2010

Supplier: Polyflor Australia Pty Ltd (59-65 Wedgewood Road, Hallam, VIC, 3803)

Sample Description: Polysafe Corona PUR Safety vinyl flooring 2.0mm, Shade: 5530 Otter, 2.40 kg/m², Batch: 1D029

Date Tested: September 2010 (Tested by FORAY Laboratories – ISO 17025 Accredited)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design IEQ-13 Green Star Office Interiors IEQ-11</p>	<p align="center">Polysafe Corona PUR</p>
<p>Total Volatile Organic Compound emission rate <0.5 mg/m²/hr</p>	<p>Total Volatile Organic Compound emission rate 0.03 mg/m²/hr</p>
<p><i>The Green Building Council of Australia recommends a threshold limit of 0.5 milligrams per square meter per hour; in accordance with this threshold this product would meet the recommended requirements.</i></p>	

The above results can be considered as representative of the Coated Safety Range of Vinyl Flooring including Polysafe Astral PUR, Polysafe Mosaic PUR and Polysafe Vogue Ultra PUR as advised by Polyflor Australia Pty Ltd.



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CV100838