

Emission Test Certificate

Thursday October 9th, 2008

Supplier: Armacell Engineered Foams (13 – 17 Nathan Road, Dandenong Victoria 3175)

Product Description: FR Armaflex

Date Tested: September 2008

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

FR Armaflex	Total Volatile Organic Compound Specific Area Emission Rate mg/m²/hr
24 hours	0.48
This product can be classed as low VOC-emitting. The material emissions are less than the recognised threshold of 0.5 mg/m ² /hr; e.g. “Green Star”.	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CV080922